## **PURCHASE REQUEST**

+ M. (how - 1270

**BOHOL PROVINCIAL GOVERNMENT** olk'In **Province of Bohol** Department: Bohol Environment Management Office **Ecological Solid Waste Management** PR No: Date: Sept. 09,200 SA No .: Date:\_ CB3 ALOBS No: Date: Item No. Item Description Quantity Unit Un Cost **Total Cost** Procurment of Dry Type Transformer Dry Type Transformer Specifiaction: Capacity: 15 KVA Input : 220 440 Output: 440 220 Output Power: 3Ø, 60 Hertz with ground Configuration: Auto Tye; Continuous Conductor: Aluminum RSCH Insulation: Class H (220°), indoor type with high 1. grade silicon core at 150° 1 pc 92,000.00 92,000.00 Enclosure: Nema 1, Indoor, Gray Color Installation: Floor Mounted Dimension (approx) 22x15" x 20" inches, 70Kg Inclusion: After sales services and installation Place of Delivery: Capitol STP Date of Delivery: 75 days upon receipt of NTP **Mode of Procurement Public Bidding** Purpose: To have suffecient power supply for the blower and aquarator of the Sequence Batch Reactor of the Capitol 92,000.00 STP for continous operation for operation and efficient treatment process of the wastewater Approved: Recommended by: Ok as to availability of funds: ATTY. ARTHUR C. YAP By Authority of the Governor: Signature: Printed Name: JOVENCIA B. GANUB. EnP EUSTAQUO A. SOCORIN Designation: Head, G.O BEMO Provincial Treasurer DUTY AUTHORIZED REV ENTATIVE

